

*Consortium for
Electric
Reliability
Technology
Solutions*

**Reliability
Performance
Monitoring
(RPM)
Prototype**

RPM Prototype Preliminary Validation Results, User Interface, Deployment Plan and Field Test

By: Carlos Martinez – CERTS/ASR,
Pete Sauer and Alejandro Dominguez-Garcia – University of Illinois
Carmel, Indiana, March 22, 2012

Presentation Outline

- RPM Prototype Objectives
- Description of MISO Phasor Data Available for RPM Prototype
- Review CERTS Monitoring Applications Portfolio and Reliability Research as Leverages for RPM Portfolio
- Review Propose Model-Less Algorithms and 3 Performance Grid Metrics – Univ. of Illinois
- Review Prototype’s Algorithms and Metrics Preliminary Validations Results for “Normal” and Disturbance” Days - Univ. of Illinois
- Review, Discuss and Agree on Prototype Notifications and User Interface and Daily Reliability Performance Report
- Review Action Items, Deployment Schedules and Field Test

RPM Prototype Goals and Objectives

The objectives of the Reliability Performance Monitoring (RPM) project are: research, functional specification, deployment, and field test of a prototype real time monitoring application using model-less algorithms producing integrated Load-Generation control and Grid Reliability performance metrics, presented via consistent user notifications and a graphic interface, running with MISO phasor data in MISO phasor infrastructure

MISO BPS Transmission Lines with Phasor Measurements at Both Ends

Line	Transmission Line Name
1	DSY5 - Roseau (Forbes)
2	DSY230 - Laverendrye (11)
3	DSY230 - Laverendrye (15)
4	Arpin - Rocky Run
5	Goodland - Morrison Ditch
6	Montgomery - Labadie #4
7	Gibson - Merom
8	AB Brown - Gibson
9	Bloomington - Worthington
10	Worthington - Merom
11	Hanna - Stout
12	Hanna - Sunnyside
13	Sunnyside - Gwynnville

Note: Expected number of MISO critical flowgates 3 to 5 times in 3 years


MISO 345KV BPS Area Used for Prototype Preliminary Validations




RPM Prototype – Part of CERTS

Portfolio of Reliability Monitoring Applications


PRIMARY CONTROL MONITORING




SECONDARY CONTROL MONITORING




TERTIARY CONTROL MONITORING




TIME ERROR CONTROL/CORRECTION MONITORING



LOAD-GENERATION-GRID ADEQUACY PERFORMANCE



Performance Metrics and Process to Produce RPM Reports



C
O
M
P
L
E
T
E
D

I
N
P
R
O
G
R
E
S
S

*Describe Model-Less Algorithms and
Propose 3 Performance Metrics for MISO*

Phasor Data Requirements

- The set of measured quantities include
 - Line-to-line voltages at both ends of the line
 - 3-phase complex power flowing into both ends of the line
- Measured quantities are sampled ten times per second
- Pseudo-measurements of line currents are obtained from the relation between complex power, voltage, and current
- Least Squares Errors (LSE) estimation is used to obtain per-second estimates of measurements and pseudo-measurements
- Since the system is at off-nominal frequency, phasor measurements rotate at a speed equal to the difference between the actual system frequency and the nominal frequency
 - To compensate for this effect, voltage estimates are redefined by defining the angle on one of the line ends to be zero and adjusting all other angles accordingly

Per-Second Voltage Estimate

- Phasor voltages measured on ends 1 and 2:

$$\bar{V}_{1j} = V_{1j} \angle \theta_{1j}$$

$$\bar{V}_{2j} = V_{2j} \angle \theta_{2j}$$

where $j=1,2,\dots,N$ indexes the samples taken every second


- Per-second voltage and estimate:

$$\hat{V}_{1\phi}[i] = \frac{\sum_{j=1}^N V_{1\phi}[i,j]}{N}, \quad \hat{\theta}_{1\phi}[i] = \frac{\sum_{j=1}^N \theta_{1\phi}[i,j]}{N} - \frac{\pi}{6},$$


$$\hat{V}_{2\phi}[i] = \frac{\sum_{j=1}^N V_{2\phi}[i,j]}{N}, \quad \hat{\theta}_{2\phi}[i] = \frac{\sum_{j=1}^N \theta_{2\phi}[i,j]}{N} - \frac{\pi}{6},$$

where voltage magnitudes are line-to-neutral

- A Similar calculation is conducted for the currents.



Stability limits



- For Stability limits, it is necessary to obtain an estimate of the angle-across-system
 - The angle-across-system can be calculated after obtaining two external system equivalents as seen from both ends of the monitored transmission line
- These external equivalents are two simple per-phase Thevenin equivalents, where it is assumed that
 - The Thevenin impedance is purely imaginary (resistance neglected)
 - The magnitude of the Thevenin voltage source is known and equal to the nominal voltage of the line monitored

Thevenin Parameter Estimation

- Let E_1 and E_2 denote the Thevenin voltages on ends 1 and 2 of the line respectively, and let δ_1 and δ_2 be the Thevenin voltage angles
- Let X_1 and X_2 be the corresponding Thevenin impedances.
- Per-second estimates can be obtained by solving:

$$A_1[i] \cdot \hat{X}_1[i]^2 + B_1[i] \cdot \hat{X}_1[i] + C_1[i] = 0,$$

$$A_2[i] \cdot \hat{X}_2[i]^2 + B_2[i] \cdot \hat{X}_2[i] + C_2[i] = 0$$

where

$$A_1[i] = \hat{I}_{1\phi}[i]^2 - \hat{I}_{1\phi}[i-1]^2,$$

$$B_1[i] = 2\hat{I}_{1\phi}[i]\hat{V}_{1\phi}[i]\sin(\hat{\theta}_{1\phi}[i] - \hat{\gamma}_{1\phi}[i]) - 2\hat{I}_{1\phi}[i-1]\hat{V}_{1\phi}[i-1]\sin(\hat{\theta}_{1\phi}[i-1] - \hat{\gamma}_{1\phi}[i-1]),$$

$$C_1[i] = \hat{V}_{1\phi}[i]^2 - \hat{V}_{1\phi}[i-1]^2,$$

$$A_2[i] = \hat{I}_{2\phi}[i]^2 - \hat{I}_{2\phi}[i-1]^2,$$

$$B_2[i] = 2\hat{I}_{2\phi}[i]\hat{V}_{2\phi}[i]\sin(\hat{\theta}_{2\phi}[i] - \hat{\gamma}_{2\phi}[i]) - 2\hat{I}_{2\phi}[i-1]\hat{V}_{2\phi}[i-1]\sin(\hat{\theta}_{2\phi}[i-1] - \hat{\gamma}_{2\phi}[i-1]),$$

$$C_2[i] = \hat{V}_{2\phi}[i]^2 - \hat{V}_{2\phi}[i-1]^2.$$

Reliability Measures Definition

- Let δ_{12}^{max} be the maximum angle-across-system that ensures small-signal stability
- A per-second stability margin index (i indexes seconds) can be defined as:

$$L^s[i] = \frac{\delta_{12}^{max} - \hat{\delta}_{12}[i]}{\delta_{12}^{max}}.$$

- These per-second indices are the basis for defining stability margin reliability measures. For a one-hour period:
 - Normalized smallest angle-across-system margin

$$H^s = \max_i \{L^s[i]\}, \quad i = 1, 2, \dots, 3600,$$

- Average angle-across-system margin

$$AVG_1^s = \frac{1}{3600} \sum_{i=1}^{3600} L^s[i] = \frac{\delta_{12}^{max} - \frac{1}{3600} \sum_{i=1}^{3600} \hat{\delta}_{12}[i]}{\delta_{12}^{max}}.$$


- Similar measures can be defined for thermal ratings and voltage bounds

Preliminary Test Environment and Data


1. MISO Line-4, STA1 and STA2
2. MISO 24-Hours of 30 Sample/Second Phasor Data for 08/17/11 – Normal Operations Day
3. MISO 24-Hours of 30 Samples/Second Phasor Data for 03/02/12 – Disturbance Day

***MODEL AND METRICS VALIDATION
USING 08/17/11 DATA
“NORMAL OPERATIONS DAY”***


System Angle Difference Using PMU Data for 8/17/11 – Normal Day



Angle Across System Stability Margin - 08/17/11




Voltage Largest Deviation Reliability Measure 08/17/11




***FREQUENCY AND VOLTAGE ALARMS
IDENTIFICATION CRITERIA
UNSING 03/02/12 DATA
“DISTURBANCE DAY”***

Frequency Events Identification Criteria Event for Event on 03/02/12 at 14:53 in Eastern


A frequency event is detected, captured and archived if during a 15-second rolling window the frequency jumps beyond a pre-defined threshold for each Interconnection



STA1 Voltage-Current 24-Hour Profile Using Phasor 03/02/12 Data – Disturbance Day




STA1 Voltage-Current 10-Minute Profile Using Phasor 03/02/12 Data



STA1 Voltage-Current 15-Second Profile Using Phasor 03/02/12 Data

A voltage event is detected, captured and archived if during a XX-second rolling window the voltage in “critical stations” jumps beyond pre-defined YY -thresholds



PROPOSE PROTOTYPE NOTIFICATIONS AND USER INTERFACE

***DAILY AND ON-DEMAND
RELIABILITY REPORT***

Daily Report Template – Pages 1-2

1. INTRODUCTION

The objective of this report is to provide a daily summary of load-generation control and Grid reliability performance for the MISO Bulk Power System (BPS) using phasor measurements. The MISO daily report presents:

Largest Frequency and Voltage Event of the Day:

- Frequency-Time profile for the largest frequency event of the day
- Estimation of Frequency Response and key parameters for largest frequency event
- Voltage-Time profile for the largest voltage event of the day
- Estimation of Voltage and key parameters for largest voltage event

Grid Adequacy Performance Section:

- Summary table with largest stability, voltage and thermal margins for key transmission lines
- Statistical performance boxplot charts for the voltage and current profiles at key transmission lines.

2. LARGEST FREQUENCY AND VOLTAGE EVENTS OF THE DAY

2.1 Largest Frequency Event Data - 1 Second Frequency Time Graph

Event Frequency at points A, B, and C are shown in the frequency response table. The frequency for this event dropped 0.065Hz (point-A - point-C) and stabilized (point-B) in 21 seconds.



Fig 1 - 1-Second Frequency-Time Graph (Extend to 15 Minutes)

2.2 Largest Frequency Event Data - Estimated Frequency Response

The event reached a lowest frequency of 59.942 (Point C) Hz and started returning to normal in about 21 seconds.

DISCLAIMER- The event Frequency Response is an approximate estimate value using the best available 1-second phasor frequency data. ACE 1-minute SCADA data, and equations shown below whose definition is being developed by NERC Subcommittees and Frequency Response Standard Drafting team. Provided solely for informational purposes	
FR = MWLoss/10*DeltaFreq	MWLoss = Max(DeltaACE(BA)) - Const*10*FreqBias*DeltaFreq
DeltaFreq = FreqA - FreqB	EI Const = 0.6, WI Const = 0.6, ERCOT = 0.3
FreqA=Avg of t-2Sec to t-16Sec	
FreqA=Avg of t+19Sec to t+52Sec	
Event Summary: Date/Time	3/2/2012 2:53:18 PM
Frequency at Point A [Hz]	60.007
Frequency at Point B [Hz]	59.94
Delta Frequency	-0.067
BA with Highest Delta ACE	PJM
Highest Delta ACE [MW]	-1239
FreqBias of the BA [MW/0.1Hz]	-1497
MW Loss [MW]	1841
Estimated Event FreqResp [MW/0.1Hz]	-2747

The interconnection responded to the largest event with an estimated frequency response of about -2747 MW/0.1Hz over performing the yearly committed value of -2601 MW/0.1 Hz. (additional performance parameters will be included)

2.3 Largest Voltage Event Data - 1 Second Voltage - Current Time Graph

Figure 2 shows the voltage and current profiles at a sub-second resolution during the 03/02/12 disturbance at 14:53 EST.




Fig 2 - Voltage and Current Profile at Disturbance on 03/02/12 at 14:53 EST

2.3 Largest Voltage Event Data - Estimated Response

Table with significant voltage event parameters (WORK IN PROGRESS)

Voltage Event Parameters				

3. MISO GRID ADEQUACY PERFORMANCE

3.1 Summary Table with Largest Stability, Voltage and Thermal Margin for Key Transmission Lines

The summary table below shows the MISO transmission line with the most critical and risky margins during the last 24 hours.

MISO Grid Performance Margins					
Hour	MISO Transmission Line	ANGLE MARGIN	VOLTAGE MARGIN	THERMAL MARGIN	Observations
20	STA1 - 2	0.309	0.718	NA	
21	STA2 - 3	0.309	0.718	NA	
22	STA3 - 4	0.309	0.718	NA	
22	STA4 - 5	0.309	0.718	NA	
19	STA5 - 6	0.309	0.718	NA	
23	STA6 - 7	0.309	0.718	NA	

3.1 Statistical Performance Boxplot Chart for the Voltage and Current Profiles at Key Transmission Lines

The boxplot show the voltage and current distribution for each hour of the day.




Fig 3 - Voltage and Current Distribution For Each Hour of the Day for STA1

Next Action Items for Deployment at MISO of RPM Prototype

- CERTS – Complete model/metrics validation using 03/02/12 phasor data – “Disturbance Day”
- CERTS – Tune model, metrics and thresholds for MISO, using phasor data for Eastern 2011 five largest frequency events, and five most critical lines from MISO list of 13 lines
- MISO to Review CERTS Prototype Functional Specification and continue and complete Prototype deployment
- CERTS to prepare and submit Prototype Field Test plan
- CERTS-MISO Field Test execution
- CERTS Final Report

RPN Prototype Deployment at MISO

Plan and Schedule

No.	Deployment Activity	Est. Comp. Date
1	CERTS - Presentation of Prototype preliminary validation results at MISO	03/22/2012
2	CERTS - Complete Prototype validations results using 03/02/12 phasor data	04/13/2012
3	MISO-Review Prototype Functional Spec. and give feedback to CERTS	04/18/2012
4	CERTS- Calibrate Prototype models, metrics and thresholds using phasor data for 5 largest Eastern frequency events and 5 MISO critical lines MISO – Verify Prototype final models and results	05/26/2012
5	MISO – CERTS Continue and complete Prototype Deployment	??/??/2012
6	CERTS – MISO Define and Create Prototype Field Trial plan	06/15/2012
7	CERTS-MISO – Execute Field Trial	07/27.2012
8	CERTS – MISO Final Report, Conclusions, Recommendations	09/14/2012